

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 EU - Type Examination Certificate Number: **Baseefa19ATEX0043X**

4 Product: **Range of 3 Phase A.C. Squirrel Cage Induction Motor.**

5 Manufacturer: **Bharat Bijlee Limited**

6 Address: **No.2, MIDC, Thane- Belapur Road ,
Airoli, Navi Mumbai- 400 708, MAHARASHTRA, INDIA.**

7 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. **GB/BAS/ExTR19.0084/00**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018 EN 60079-1:2014

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

Ⓢ II 2G Ex db IIB T6..T4* Gb (Tamb = -20°C to +°C) *See schedule**

SGS Baseefa Customer Reference No. **6409**

Project File No. **18/0421**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail baseefa@sgs.com web site www.sgs.co.uk/sgsbaseefa

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

BAS-CERT-003

Issue 3



R S SINCLAIR

TECHNICAL MANAGER

On behalf of SGS Baseefa Limited

M POWNEY
Certification
Manager

13

Schedule

14

Certificate Number Baseefa19ATEX0043X

15 Description of Product

The F80 to F315 series are Squirrel Cage Induction Motors .The motors comprise stator frame and end covers. The stator frames are fitted with main terminal box and auxiliary terminal box or alternatively an accessory box can be fixed on the main terminal box. The terminal box is attached to the stator frame and “lead wires” are brought inside the terminal box for connection to the external supply through the moulded terminal bushings cemented inside the terminal box.

The method of cooling is TEFC (Totally enclosed fan cooled).The motors are fitted with external cooling fans and fan covers at the non-drive end. The motor frame, end covers and bearing covers are manufactured from cast iron grade FG200 alternate material can be, cast iron grade FG260, mild steel (grade-E250) or SG Iron 450/10. Shaft material is carbon steel EN8, alternate material can be EN24/EN57, stainless steel SS304/SS316 or forged steel grade 35C8/45C8/55C8.The shaft is mounted on grease lubricated ball bearings and provided with shaft seals at both the ends. The end shields are fastened to the motor frame by socket head cap screws on each side. All metric fasteners used for assembling the motor are high tensile carbon steel socket head cap screws of property class 8.8 with minimum yield stress of 640 MPa.

The clearance between fan and all stationary parts is more than 5 mm. The fan guard meets the requirements of IP20 and the mechanical strength requirements of the reference standard. The rotor is die cast aluminium type, alternatively permanent magnets may be embedded in the rotor core. The squirrel cage induction motor with embedded permanent magnet in the rotor core are known as “Line Start Permanent Magnet Synchronous Motors”.

Space heaters may be fitted to the overhang and energized with suitable power rating. A specific condition of use is that the heaters must only be switched on when the motor is de-energized.

The stator windings consist of enamelled copper wire suitable for insulation class F or better and impregnated with suitable varnish. PTC thermistors can be provided with the motors for thermal protection.

Rating:

These ranges of motors are manufactured in different ratings as shown in the table 1 below with three phase electrical supply, The motors are rated up to 690 V, 50/60 Hz & S1 duty with a supply variation no more than $\pm 5\%$ on frequency and $\pm 10\%$ on voltage or combined variation of $\pm 10\%$ (corresponding to Zone B in IEC 60034-1 clause 7.3).

TABLE 1

Frame size	Maximum Output in kW							
	2 Pole		4 Pole		6 Pole		8 Pole	
	50Hz	60Hz	50Hz	60Hz	50Hz	60Hz	50Hz	60Hz
F 80	1.1	1.3	0.75	0.90	0.55	0.60	N.A.	N.A.
F 90L	2.2	2.5	1.5	1.7	1.1	1.3	0.55	0.63
F 100L	3.7	4.3	2.2	2.5	1.5	1.7	1.1	1.3
F 112M	N.A.	N.A.	3.7	4.3	2.2	2.5	1.5	1.7
F 132S	7.5	8.6	5.5	6.3	3.7	4.3	2.2	2.5
F 132M	9.3	11	7.5	8.6	5.5	6.3	N.A.	N.A.
F 160M	15	17	11	13	7.5	8.6	5.5	6.3
F 160L	18.5	21	15	17	11	13	7.5	8.6
F 180L	22	25	22	25	15	17	11	13

Frame size	Maximum Output in kW							
	2 Pole		4 Pole		6 Pole		8 Pole	
	50Hz	60Hz	50Hz	60Hz	50Hz	60Hz	50Hz	60Hz
F 200L	37	43	30	35	22	25	15	17
F 225S	N.A.	N.A.	37	40	N.A.	N.A.	18.5	20
F 225M	45	50	45	50	30	33	22	24
F 250M	55	60	55	60	37	40	30	33
F 280S	75	83	75	83	45	50	37	40
F 280M	90	100	90	99	55	61	45	50
Frame size	Maximum Output in kW							
	2 Pole		4 Pole		6 Pole		8 Pole	
	50Hz	60Hz	50Hz	60Hz	50Hz	60Hz	50Hz	60Hz
F 315S	110	116	110	115	75	79	55	58
F 315M	132	140	132	140	110	115	90	95
F 315L	180	190	200	210	160	168	132	140

TABLE 2

- Motors with S3/S4 duty, 150/300 starts/hour, CDF 25%, 40%, 60%, 50Hz/ 60Hz

Frame Size	Maximum Output in kW		
	4 Pole	6 Pole	8 Pole
F 80	0.75	0.55	N.A.
F 90L	1.5	1.1	0.55
F100L	2.2	1.5	1.1
F 112M	3.7	2.2	1.5
F 132S	5.5	3.7	2.2
F 132M	7.5	5.5	N.A.
F 160M	9.3	6.0	4.2
F 160L	12.5	9.3	6.0
F 180L	15.0	12.5	9.3
F 200L	24.0	17.0	12.0

- Motors with S3/S4 duty, 150 starts/hour, CDF 25%, 40%, 60%, 50Hz/ 60Hz

Frame Size	Maximum Output in kW		
	4 Pole	6 Pole	8 Pole
F 225M	33.0	22.0	16.0
F 250M	40.0	28.0	22.0
F 280S	52.0	35.0	30.0
F 280M	64.0	40.0	35.0

TABLE 3

The motor (*) temperature class and the maximum (**) ambient temperature ranges are as described in the table below

Frame size	*Temperature Class ** Max. Ambient Temperature °C			
	**40	**50	**55	**60
F 80	*T6	*T5	*T5	*T4
F 90L	*T5	*T5	*T4	*T4
F 100L	*T5	*T5	*T4	*T4
F 112M	*T5	*T5	*T4	*T4
F 132S	*T4	*T4	*T4	*T4
F 132M	*T4	*T4	*T4	*T4
F 160M	*T4	*T4	*T4	*T4
F 160L	*T4	*T4	*T4	*T4
F 180L	*T4	*T4	*T4	*T4
F 200L	*T4	*T4	*T4	*T4
F 225S	*T4	*T4	*T4	*T4
F 225M	*T4	*T4	*T4	*T4
F 250M	*T4	*T4	*T4	*T4
F 280S	*T6	*T5	*T5	*T4
F 280M	*T4	*T4	*T4	*T4
F 315S	*T4	*T4	*T4	*T4
F 315M	*T4	*T4	*T4	*T4
F 315L	*T4	*T4	*T4	*T4

ALTERNATIVE FEATURES / ALTERNATIVE PERMISSIBLE VARIATIONS WITH CONDITIONS WHERE APPLICABLE

- 1) Class of insulation can be “H” or better.
- 2) Motors can have various mounting like foot mounting, face mounting, flange mounting, foot, flange/ face mounting, double flange mounting or pad / rod mounting.
- 3) Method of cooling may be TESC (Totally enclosed surface cooled), TEFC (totally enclosed fan cooled) or totally enclosed force cooled type. For self-ventilated motors in case of forced air stream application, the fan and fan cover shall be omitted. The motor used for force cooling should be IECEx/ATEX Zone 1 approved type with IP66 protection.
- 4) The position of terminal box with respect to mounting foot may be at 90° or 180° or at any intermediate angle.
- 5) The motor shaft may be offered with carbon steel EN8 material, alternate material can be EN24/EN57, stainless steel SS304/SS316 or forged steel grade 35C8/45C8/55C8.. The motor may be provided with shaft extension at non driving end.
- 6) Socket head cap screws of better property class than 8.8 and stainless steel material can be used
- 7) Deep groove ball / angular contact ball / cylindrical roller / Tapered roller bearings can be provided. Bearings can be of shielded type Z or 2Z/ZZ, sealed type RS or 2RS.

- 8) The rotor is die cast aluminium type, alternatively permanent magnets may be embedded in the rotor core. The squirrel cage induction motor with embedded permanent magnet in the rotor core are known as “Line Start Permanent Magnet Synchronous Motors”.

Rating chart of Line Start Permanent Magnet Synchronous Motors is as indicated in below Table-4

TABLE 4

Frame size	Pole	Max output in kW
F112M	4	1.5
		2.2
F132S		3.7
		5.5
F132M		7.5
F160M		11
F160L		15
F180L		18.5
F200L		30

- 9) Motors can only be provided with space heaters, provided the maximum surface temperature of the space heater is well within the applicable temperature class of the motor.
- 10) The motors are continuously rated for S1 or S2-60 minutes duty as defined in EN/IEC 60034-1 for connection to three phase supply having form and symmetry at least as described in EN/IEC 60034-1.
- 11) Alternative temperature classifications with de-rated output, alternative duty cycles, dual voltage as indicated in Table 5 below :-

TABLE 5

Item	Temperature classification “T3”	Temperature classification “T4”	Temperature classification “T5”	Temperature classification “T6”	Condition
Standard output as Table-1	All outputs as Table-1	All outputs as Table-1	a) All outputs as Table 1 for frame 80-112M & frame 280S b) All outputs derated to 70% with 90 deg C thermistors in each winding for frame other than above frames.	a) All outputs as Table 1 for frame 80 & frame 280S. b) All outputs as table no.1-derated to 50% with 80 deg C thermistor in each winding for frame other than above frames.	S1 & S2-60 minutes duty. 50/60 Hz

Item	Temperature classification "T3"	Temperature classification "T4"	Temperature classification "T5"	Temperature classification "T6"	Condition
Insulation class F, H and above and temperature rise limited to class B	All outputs as Table-1	All outputs as Table-1	a) All outputs as Table 1 for frame 80-112M & frame 280S b) All outputs derated to 70% with 90 deg C thermistors in each winding for frame other than above frames	a) All outputs as Table 1 for frame 80 & frame 280S. b) All outputs as table no.1-derated to 50% with 80 deg C thermistor in each winding for frame other than above frames.	S1 & S2-60 minutes duty. 50/60 Hz
Insulation class F,H and above and temperature rise limited to class F	All outputs as Table-1	All outputs as Table-1 derated to 70% with 130 deg.C thermistor in each winding	Not applicable	Not applicable	S1 & S2-60 minutes duty. 50/60 Hz
Duty from S3 to S4	All outputs as Table-2 with 150°C thermistors in each winding	All outputs as Table-2 with 130°C thermistors in each winding	All outputs as Table -2 de-rated to 60% with 90°C thermistors in each winding	All outputs as Table -2 de-rated to 50% with 80°C thermistors in each winding	Insulation class F,H and above. Temperature rise limited to Class B or F. 50/60 Hz
Dual voltage with star/delta connections with flux and current densities as rated voltage	All outputs as Table-1	All outputs as Table-1	a) All outputs as Table 1 for frame 80-112M & frame 280S b) All outputs derated to 70% with 90 deg C thermistors in each winding for frame other than above frames.	All outputs as Table -1 de-rated to 50% with 80°C thermistors in each winding	S1 & S2 - 60 minutes duty. Insulation class F,H and above. Temperature rise limited to Class B or F. 50/60 Hz
Ambient temperature above 40°C up to 50°C	All outputs as Table-1	All outputs as Table-1	a)All outputs as Table 1 for frame 80-112M & frame 280S b) All outputs derated to 60% with 90 deg C thermistors in each winding for frame other than above frames	All outputs as Table -1 de-rated to 50% with 80°C thermistors in each winding	S1 & S2 - 60 minutes duty . Insulation class F ,H and above. Temperature rise limited to Class B or F . 50/60Hz.

Item	Temperature classification "T3"	Temperature classification "T4"	Temperature classification "T5"	Temperature classification "T6"	Condition
Ambient temperature above 50°C up to 60°C	All outputs as Table-1	All outputs as Table-1	a) All outputs as Table 1 derated to 80% for frame 80-112M & frame 280S b) All outputs derated to 50% with 90 deg C thermistors in each winding for frame other than above frames	All outputs as Table -1 de-rated to 50% with 80°C thermistors in each winding	S1 & S2 - 60 minutes duty . Insulation class F ,H and above. Temperature rise limited to Class B or F . 50/60Hz.

16 Report Number

GB/BAS/ExTR19.0084/00

17 Specific Conditions of Use

- The manufacturer has maintained more stringent gaps than those required by the standard. The user must refer to manufacturer before carrying out any repairs or refurbishment to the equipment.
- Space heaters (if provided) shall be energized only after disconnecting main supply of motor.
- The fastening screws shall be of high tensile carbon steel socket head cap screws of property class 8.8 with minimum yield stress of 640 MPa.
- When PTC thermistors are used, they shall be connected into a control circuit such that the motor is disconnected from the supply in the event of a winding reaching the temperature rating of the thermistor as listed in Table 5 of this certificate.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
1.2.7	LVD type requirements
1.2.8	Overloading of equipment (protection relays, etc.)
1.4.1	External effects
1.4.2	Aggressive substances, etc.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
2.35.800.011	1 to 18	00	16/06/2018	Flameproof Motor Group IIB General Construction Details
71045-1	-	00	16/06/2018	Different Types Of Construction (Method of mounting)

These drawings are associated with, and held with IECEx BAS 19.0036X.